



単位:mm

受口 記号 呼径	主 管 (下流)						枝 管					
	d ₁ 基準寸法	d ₂ 基準寸法	d ₁ 及びd ₂ の許容差	D	d	l	d ₁ 基準寸法	d ₂ 基準寸法	d ₁ 及びd ₂ の許容差	D	d	l
75	89.45	88.65	±0.30	97.0	77.2	40	89.45	88.65	±0.30	97.0	83.0	40
100	114.55	113.55	±0.35	124.0	98.8	50	114.55	113.55	±0.35	124.0	107.0	50
100X 75							89.45	88.65	±0.30	97.0	83.0	40

単位:mm

記号 呼径	d'	l'	Z ₁	Z ₂	Z ₃	L ₁	L ₂	L ₃
75	90	80	40.0	63.0	50.0	80.0	143.0	90.0
100	115	100	53.0	80.0	63.0	103.0	180.0	113.0
100X 75			39.0	66.0	62.0	89.0	166.0	102.0

図名

TNS 100° T 寸法図

東栄管機株式会社